



GRANVILLE B. VICKERMAN & ASSOCIATES

Consulting Engineers + Project Managers

ADDENDUM NO. 2

***Project Site: ASSIGINACK ARENA BUILDING
Project Description: Entrance Addition & Interior Alteration
Address: 59 Vankoughnet St; Manitowaning, Ontario***

The following shall form part of the instructions to bidders.

At the Exercise Room, include for the following electrical 20amp receptacles.

- Treadmill: 2
- Bikes: 6
- Elliptical mini bands: 3
- Elliptical probands - blue: 2
- Elliptical probands – green: 2

Receptacles shall be connected to electrical floor tracks and mounted to the rubber flooring in heavy-duty cable protector cover ramps.

Exact locations to be determined on site by Owner.

Acceptable manufacturers are: NEDCO; FASTENAL; ATLAS or equal.